



CITY OF O'FALLON, MISSOURI
PURCHASING DEPARTMENT

100 North Main Street
O'Fallon, MO 63366
T: (636) 379-5527

BID NUMBER:	23-014	BID ISSUE DATE:	02/03/2023
BID DESCRIPTION:	CARSHIELD FIELD LIGHTING RE-LAMP		
BID OPENING DATE:	02/16/2023	BID OPENING TIME:	2:30 P.M. CST

February 10, 2023

ADDENDUM #1

The purpose of this addendum is to recap the discussion of the optional pre-bid meeting held at 10:00AM CST on 02/09/2023 located at 900 TR Hughes Blvd., O'Fallon MO 63366 and to address all other questions received on or before 02/09/2023 at 12:00PM CST. The time period for questions is closed.

Attendees:

Dave Moyers, City of O'Fallon
Donna Pinkston, City of O'Fallon

Companies in attendance:

Reinhold Electric

I. Meeting:

The meeting was opened by describing and discussing the project description, the bid requirements, and the project specifications.

II. Questions:

1. Is there access to the light poles without using the field?

Answer: No. Please note: Proper protection is necessary when accessing the field with heavy equipment.

2. If there are more sockets needed, would we need to supply those or will the City provide them?

Answer: The City has sockets and can provide them upon request.

3. Will the lower lights on the poles need to be re-lamped?

Answer: Yes, all lights on the poles with need to be replaced regardless of the location on the pole.

Note: There is a \$2,500 contingency built into the base bid for unforeseen items. Items that require the use of the contingency will need to be pre-approved.

Other Questions Received:

1. Please advise whether O'Fallon will consider switching to LED fixtures from Metal Halide as this would save approx.. 60% on energy costs while dramatically upgrading lighting quality. Metal Halide is an obsolete inefficient technology that provides inferior lighting quality.

Answer: No, not at this time.

2. Are you interested in receiving an alternate bid for installing new LED fixtures instead of replacing the existing HID bulbs and ballasts? The total value would be much better for the City to upgrade to LED than keep HIDs.

- Answer: No, this bid is to re-lamp with metal halide.

Reminder:

The due date and time remain the same for this project. This is to remind all bidders that sealed bids for bid #23-017 CarShield Field Lighting Re-Lamp must be submitted by 2:30 P.M. CST, February 16, 2023, to:

Christine Grabin, Purchasing Agent
City of O'Fallon, Missouri
100 North Main Street
O'Fallon, Missouri 63366

Addendum information will be available over the Internet at www.ofallon.mo.us. Adobe Acrobat® Reader may be required to view this document. We strongly suggest that you check for any addenda a minimum forty-eight hours (48) in advance of the bid deadline. Due to revisions, the bidders must acknowledge the Addendum(s) on the bid form.

Attachments: Pre-Bid Meeting Sign-In Sheet

END OF ADDENDUM #1

Site visit attendee sign in

Project: Carshield Field Lighting re-lamp, Bid#23-014

Date/Time: 2/9/2023 10:00am

Bid opening date/time: 2/16/2022, 2:30pm

Name	Business Name	Phone number	Email address
Mike Giger	Reinhold Electric	314-714-8841	MGiger@reinholdelectric.com
City employees: Dave Moyers Donna Pinkston			

NOTES: _____

