



CITY OF O'FALLON, MISSOURI
PURCHASING DEPARTMENT

100 North Main Street
O'Fallon, MO 63366
T: (636) 379-5527

BID NUMBER:	23-092	BID ISSUE DATE:	12/01/2023
BID DESCRIPTION:	CITY HALL WATER HEATERS		
BID OPENING DATE:	12/14/2023	BID OPENING TIME:	3:00 P.M. CST

December 8, 2023

ADDENDUM #1

The purpose of this addendum is to recap the discussion of the optional pre-bid meeting held at 9:30 A.M. CST on 12/07/2023 at the O'Fallon City Hall, located at 100 North Main Street, O'Fallon, MO 63366, to make changes to the specs, and to address questions received on or before 12/08/2023 at 12:00 P.M. CST. The time period for questions is closed.

Attendees:

Mike Leonard, City of O'Fallon

Companies in attendance:

IFS

I. Meeting:

The meeting was opened by describing and discussing the project description, the bid requirements, and the project specifications.

II. Changes:

1. Change type of copper from "Type K" to "Type L".
2. Do not install seismic bracing.
3. Replacement of the gas regulator should be included in the total bid price if needed.

III. Questions:

No questions were received on this project before or after the pre-bid meeting.

Reminder:

The due date and time remain the same for this project. This is to remind all bidders that sealed bids for bid #23-092 City Hall Water Heaters must be submitted by 3:00 P.M. CST, December 14, 2023, to:

Christine Grabin, Purchasing Agent
City of O'Fallon, Missouri
100 North Main Street
O'Fallon, Missouri 63366

Addendum information will be available over the Internet at www.ofallon.mo.us. Adobe Acrobat® Reader may be required to view this document. We strongly suggest that you check for any addenda a minimum forty-eight hours (48) in advance of the bid deadline. Due to revisions, the bidders must acknowledge the Addendum(s) on the bid form.

Attachments: Pre-Bid Meeting Sign-In Sheet

END OF ADDENDUM #1

