



CITY OF O'FALLON, MISSOURI
PURCHASING DEPARTMENT

100 North Main Street
O'Fallon, MO 63366
T: (636) 379-5527

BID NUMBER:	24-022	BID ISSUE DATE:	02/16/2024
BID DESCRIPTION:	SEWER TAP LINING		
BID OPENING DATE:	02/27/2024	BID OPENING TIME:	2:15 P.M. CST

February 22, 2024

ADDENDUM #1

The purpose of this addendum is to address all questions received on or before 02/21/2024 at 12:00 PM. The time period for questions is closed.

Questions:

1. For the above referenced Sewer Tap Lining project, are we to assume that the host pipe is 8"?

*Answer: Host could be 8", 10" or 12" if you are referring to the City's Sewer mains.
Laterals will be 4" or 6".*

Reminder:

The due date and time remain the same for this project. This is to remind all bidders that sealed bids for bid #24-022 Sewer Tap Lining must be submitted by 2:15 P.M. CST, February 27, 2024, to:

Christine Grabin, Purchasing Agent
City of O'Fallon, Missouri
100 North Main Street
O'Fallon, Missouri 63366

Addendum information will be available over the Internet at www.ofallon.mo.us. Adobe Acrobat® Reader may be required to view this document. We strongly suggest that you check for any addenda a minimum forty-eight hours (48) in advance of the bid deadline. Due to revisions, the bidders must acknowledge the Addendum(s) on the bid form.

END OF ADDENDUM #1