



CITY OF O'FALLON, MISSOURI
PURCHASING DEPARTMENT

100 North Main Street
O'Fallon, MO 63366
T: (636) 379-5527

BID NUMBER:	25-011	BID ISSUE DATE:	01/31/2025
BID DESCRIPTION:	FIRE HYDRANTS AND ACCESSORIES		
BID OPENING DATE:	02/13/2025	BID OPENING TIME:	2:30P.M. CST

February 7, 2025

ADDENDUM #2

The purpose of this addendum is to address all questions received on or before 02/05/2025 at 12:00 PM. The time period for questions is closed.

1. Are the fire hydrants 5 ¼ 3-way Fire Hydrants yellow in color, do items 1-3 have an MJ Shoe or a Alpha end connection. Are the gate valves and the anchor coupling 6"? Do the gate valves have an MJ shoe or an alpha end connection?

Answer: Hydrants yellow, MJ shoe on all fire hydrants and valves.

2. Open Right Hydrants in the past we have shipped to you open left?

Answer: Open left

3. Hydrant inlet MJ ?

Answer: MJ

4. Item # 6 size 6" ?

Answer: 6 inch

5. Item # 7 size ? and what length ? 12",18",24"

Answer: 12 inch

6. No Gland packs ? or gaskets ?

Answer: No

Reminder:

The due date and time remain the same for this project. This is to remind all bidders that sealed bids for bid **#25-011 Fire Hydrants and Accessories** must be submitted by 2:30 P.M. CST, February 13, 2025, to:

Christine Grabin, Purchasing Agent
City of O'Fallon, Missouri
100 North Main Street
O'Fallon, Missouri 63366

Addendum information will be available over the Internet at www.ofallonmo.gov. Adobe Acrobat® Reader may be required to view this document. We strongly suggest that you check for any addenda a minimum forty-eight hours (48) in advance of the bid deadline. Due to revisions, the bidders must acknowledge the Addendum(s) on the bid form.



CITY OF O'FALLON, MISSOURI
PURCHASING DEPARTMENT

100 North Main Street
O'Fallon, MO 63366
T: (636) 379-5527

BID NUMBER:	25-011	BID ISSUE DATE:	01/31/2025
BID DESCRIPTION:	FIRE HYDRANTS AND ACCESSORIES		
BID OPENING DATE:	02/13/2025	BID OPENING TIME:	2:30P.M. CST

January 31, 2025

ADDENDUM #1

The purpose of this addendum is to make a correction to the original specifications that were released on January 31, 2025.

Delete Page 24 of the original specifications

Replace with Page 2 of this Addendum #1

Reminder:

The due date and time remain the same for this project. This is to remind all bidders that sealed bids for bid **#25-011 Fire Hydrants and Accessories** must be submitted by 2:30 P.M. CST, February 13, 2025, to:

Christine Grabin, Purchasing Agent
City of O'Fallon, Missouri
100 North Main Street
O'Fallon, Missouri 63366

Addendum information will be available over the Internet at www.ofallonmo.gov. Adobe Acrobat® Reader may be required to view this document. We strongly suggest that you check for any addenda a minimum forty-eight hours (48) in advance of the bid deadline. Due to revisions, the bidders must acknowledge the Addendum(s) on the bid form.

PRICING

Fire Hydrants and Accessories:

ITEM	DESCRIPTION	UNIT	QTY	UNIT PRICE	TOTAL PRICE	ESTIMATED DELIVERY TIME ONCE ORDERED (WEEKS)
1	4' Bury Fire Hydrant	Each	5	\$	\$	
2	4.5' Bury Fire Hydrant	Each	3	\$	\$	
3	5' Bury Fire Hydrant	Each	1	\$	\$	
4	1' Hydrant Extension	Each	2	\$	\$	
5	.5" Hydrant Extension	Each	2	\$	\$	
6	MJ Gate Valves	Each	20	\$	\$	
7	MJ Anchor Couplings	Each	30	\$	\$	
8	¾" T-Bolts x 3 ½" Cor Blue	Each	850	\$	\$	
	*Total for line items #1 - #8	\$	X	X	\$	X

**Only the total for all line items will be read at the bid opening. All bids will be evaluated, by City staff, for individual line item costs and delivery timeframes.*