



CITY OF O'FALLON, MISSOURI
PURCHASING DEPARTMENT

100 North Main Street
O'Fallon, MO 63366
T: (636) 379-5527

BID NUMBER:	25-047	BID ISSUE DATE:	05/09/2025
BID DESCRIPTION:	CITY HALL PRIVACY FENCE REPLACEMENT		
BID OPENING DATE:	05/28/2025	BID OPENING TIME:	2:30 P.M. CDT

May 19, 2025

ADDENDUM #1

The purpose of this addendum is to recap the discussion of the optional pre-bid meeting held at 2:00 P.M. CDT on 05/14/2025 and to address questions received on or before 05/15/2025 at 12:00 P.M. CDT. The time period for questions is closed.

Attendees:

Mike Leonard, City of O'Fallon
Dave Moyers, City of O'Fallon

Companies in attendance:

KW Fence Co

I. Meeting:

The meeting was opened by describing and discussing the project description, the bid requirements, and the project specifications.

II. Additional Questions:

1. Looking at the scope of work for this project it is calling out the wall thickness for the post 0.147 or greater, the rails 0.080 and the slats/pickets 0.080
The standard slat/picket wall thickness is .050 - .065 depending on MFG and style. I do not know of an 0.080 wall thickness on slats/pickets.

Answer: That is fine if that is what you can source, and it will be considered as an alternative.

Reminder:

The due date and time remain the same for this project. This is to remind all bidders that sealed bids for bid #25-047 must be submitted by 2:30 P.M. CDT, May 28, 2025, to:

Christine Grabin, Purchasing Agent
City of O'Fallon, Missouri
100 North Main Street
O'Fallon, Missouri 63366

Addendum information will be available over the Internet at www.ofallonmo.gov. Adobe Acrobat® Reader may be required to view this document. We strongly suggest that you check for any addenda a minimum forty-eight hours (48) in advance of the bid deadline. Due to revisions, the bidders must acknowledge the Addendum(s) on the bid form.

Attachments: Pre-Bid Meeting Sign-In Sheet

